



Sewer Main Test Report

City _____
 Engineer © _____

Date: _____
 Weather: _____

Right-Of-Way:	Project/Subdivision Name:
Drainlayer:	Reference Plan:
Testing Company:	Inspector:

Testing procedure shall be as specified in ASTM C828-01, C924-02 and F1417-92 (or latest revisions) – Standard Test Method For Low-Pressure Air Test Of (VCP, CP and PVC) Sewer Lines, further as modified by the allowable pressure loss shall not exceed 0.5 P.S.I. within the time requirements.

Station To Station	Pipe Diameter & Type	Test Time Required	Starting Pressure (P.S.I.)	Ending Pressure (P.S.I.)	Pressure Loss (P.S.I.)	Pass Or Fail

Comments: _____

